

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50560100

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*
Jiang Tao

Unser Zeichen *Our Reference*
01-Kese-CN22BQ70 001

Ausstellungsdatum *Date of Issue*
30.09.2022 (day/mo/yr)

Genehmigungsinhaber *License Holder*
GoodWe Technologies Co., Ltd.
No.90 Zijin Rd., New District
215011 Suzhou
P.R. China

Fertigungsstätte *Manufacturing Plant*
GoodWe (GuangDe) Power Supply
Technology Co., Ltd.
No.208, Tong Rui East Road,
Guangde,
Anhui
P.R. China

Prüfzeichen *Test Mark*



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1111259844

Geprüft nach *Tested acc. to*
IEC 61851-1:2017
EN IEC 61851-1:2019

**Zertifiziertes Produkt (Geräteidentifikation)
*Certified Product (Product Identification)***

**Lizenzentgelte - Einheit
*License Fee - Unit***

EV charging station (AC Charger)

Type Designation	: GW7K-HCA	12
	GW11K-HCA GW22K-HCA	
Rated Input Voltage [Va.c.]	: 230, L/N/PE	
	400, 3L/N/PE	
Rated Output Voltage [Va.c.]	: 230, L/N/PE	
	400, 3L/N/PE	
Rated Output Current [Aa.c.]	: 32	
	16 32	
Rated Output Frequency [Hz]	: 50/60	
EV Connection type	: Case C	
EV charging mode	: Mode 3	
RCD type (External required)	: Type A 30mA	
RCD type (Built-in)	: 6 mA DC	

continued on page 0002

12

ANLAGE (Appendix): 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.



Zertifizierungsstelle

A. Chen

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
http://www.tuv.com/safety E-mail: markcheck@tuv.com
Fax: +49 221 806-3935

Zertifikat

Certificate



Zertifikat Nr. Certificate No.
R 50560100

Blatt Sheet
0002

Ihr Zeichen Client Reference
Jiang Tao

Unser Zeichen Our Reference
01-Kese-CN22BQ70 001

Ausstellungsdatum Date of Issue
30.09.2022 (day/mo/yr)

Genehmigungsinhaber License Holder
GoodWe Technologies Co., Ltd.
No.90 Zijin Rd., New District
215011 Suzhou
P.R. China

Fertigungsstätte Manufacturing Plant
GoodWe (GuangDe) Power Supply
Technology Co., Ltd.
No.208, Tong Rui East Road,
Guangde,
Anhui
P.R. China

Prüfzeichen Test Mark



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1111259844

Geprüft nach Tested acc. to
IEC 61851-1:2017
EN IEC 61851-1:2019

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

EV charging station (AC Charger)

as page 0001 continued

Degree of Protection : IP55
Protective Class : Class I
Pollution degree : PD3
Operating Temperature [°C] : -30 to 50
Altitude [m] : 2000

Remark(s) :

The installation has to be carried out according to the attached installation instruction.
Any additional requirements in countries where the product is going to be marketed have to be considered additionally.

ANLAGE (Appendix) : 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.



Zertifizierungsstelle

A. Chen

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markcheck@tuv.com
Fax: +49 221 806-3935

GoodWe Technologies Co., Ltd.
Mr. Jiang Tao

Date : 30.09.2022
Our ref. : Kese 01
Your ref.: Jiang Tao

No.90 Zijin Rd., New District
215011 Suzhou
P.R. China

Ref : R TÜV-Mark Approval

Type of Equipment : AC Charger
Model Designation : See Certificate
Certificate No. : R 50560100 0001
Report No. : CN22BQ70 001

Dear Mr. Jiang Tao,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area. In case you have a change regarding your involved local representative for the certificate, please inform us in due time.

With kind regards,

Certification Body


A. Chen

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询